

Control Panel - Options for Single and Three Phase Panels

Standard		
Description	Function	Suffix
Gas Reset Module	Used to reset electric gas valve after a power outage. Required so gas does not fill building when power is restored and pilots are not lit.	GR
Dry Contact(Additional)	COM, NC, NO contacts to be used for de-energize or energize components upon fire system discharge. Examples are audible alarm, shunt trip breakers, appliance contactors, fire alarm, etc.	DC
Gas Reset Module	Used for easy balancing without going to roof or changing drive packages on fans. Also used for motors larger than two horsepower where three phase power is not available. AC Drive can have single phase input and three phase output.	AD+HP (Example 1HP motor = AD1)
Appliance Load Contactors	Used to control electrical appliances and /or devices which need to shut-down upon fire system discharge. Customer to determine amperage required.	ALC+Amp/Volt/Ph (Example 60Amp 230v 3 phase = ALC 60/230/3)
<p>* If multiple options are taken then add suffix in order to end of Part No. Example: 1 exhaust fan, 1 supply fan with Gas Reset Module and Dry Contacts=KH110GRDC Example: 2 exhaust fan, 1 supply fan with Dry Contacts and Appliance Load Contactor for 80 amps at 230v 3 phase=KH312-DCALC 80/230/3</p>		

